#### PERMANENT BUILDING COMMITTEE SCHOOL BUILDING SUB-COMMITTEE MEETING AGENDA



Meeting Date:	January 30, 2024
Meeting Time:	6:30 PM
Project Name:	Clinton Middle School
Project Number:	202000640305
Meeting Purpose:	SBC Meeting No. 022
Location:	ZOOM
Meeting Link:	https://us06web.zoom.us/j/83692330688?pwd=PkM0wg3z2hjvXIcWYZfhka2sMKhgwf.1
Meeting ID:	836 9233 0688
Passcode:	263692
One Tab Mobile:	16468769923,,83692330688#,,,,*263692# US (New York)
Prepared By:	Elias Grijalva

- 1. Call to Order & number of voting members present.
- 2. Geothermal & PV Systems Discussion/Vote
- 3. COA Carriage House Designer Services Award
- 4. Other Topics not Reasonably Anticipated 48 hours prior to the Meeting
- 5. Public Comment
- 6. Next Meetings
- 7. Adjourn



### Clinton MIDDLE SCHOOL BUILDING PROJECT

Massachusetts School Building Authority

DORE + WHITTIER

January 30, 2024 Geothermal and Photovoltaic Systems Discussion

- 1/12/24 SD DRAWINGS AND SPECIFICATIONS TO COST ESTIMATORS
- **2/01/24 COST ESTIMATES ARE DUE**
- **2/02/24 COST ESTIMATE RECONCILIATION**
- **2/06/24 SBC/PBC PRESENTATION (COST ESTIMATE)**
- **2/09/24 SUBMIT PRESENTATION and ESTIMATE TO THE TOWN**
- 2/13/24 ALL-BOARDS MEETING
- 2/20/24 SBC VOTE TO SUBMIT SCHEMATIC DESIGN TO MSBA
- **2/23/24 SUBMIT DESE AND SD PACKAGES**

### SCHEMATIC DESIGN SCHEDULE

### PACKAGED AIR SOURCE HEAT PUMP

- Dedicated Outdoor Air Systems (DOAS)
- Packaged HVAC Systems
- **o** Inverter Variable Speed Compressors
- Energy Recovery (ERV) Wheels or Core
- **o** Hot Water or Electric Back-up Heat



## AIR SOURCE HEAT PUMP SYSTEM

### HEAT RECOVERY CHILLER/HEATER

- Generates both chilled water and hot water simultaneously
- Operation down to 0F with 130F water
- Multiple 30-ton modules (est. 150-ton+)



### HEAT RECOVERY CHILLER/HEATER

#### TRADITIONAL

#### PROPRIETARY





### GEOTHERMAL SYSTEM TYPES

# nationalgrid



Massachusetts Department of Energy Resources



	Est. Current System (ASHP only)	Est. Geothermal System (partial)	Delta
Mechanical Scope (direct cost only)	\$11,400,000	\$11,650,000	\$250,000
Geothermal Wells and Site Work	Wells \$0 \$3,000,000 rk		\$3,000,000
Subtotal	\$11,400,000	\$14,650,000	\$3,250,000
Mass Save Rebates (275 tons)	<b>(\$220,000)</b> \$800/ton	<b>(\$553,000)</b> 90 tons at \$4500/ton 185 tons at \$800/ton	(\$333,000)
IRA (est. 34%)	\$0	(\$4,981,000)	(\$4,981,000)
Estimated Total Const. Costs	\$11,180,000	\$9,116,000	(\$2,064,000)

\*All values listed in chart are estimates only and are subject to change as the project develops.

**\*\***Values do not include design fees and other ancillary fees such as test wells, etc.

\*\*\*Values do not include required added square footage to building to accommodate geothermal equipment.

GEOTHERMAL COST COMPARISON

- The Annual Heating Energy Consumption is estimated to be 190,800kWh/year.
- The Annual Heating Energy Cost is ± 190,800kWh (.22 Cents) =\$42,000/year.

System	Annual Costs	Median Service Life	
Air-Source Heat Pumps [76,320 kWh/year]	\$16,790	15-20 years	
Ground-Source Heat Pumps [76,320 kWh/year]	\$10,494	20-25 years	
	(\$6 <i>,</i> 296)	(5-10 years)	

• The savings of using geothermal equipment is estimated to be \$6,300/year

#### **Points to Note:**

• A geothermal system is expected to be 25-50% (37.5%) more efficient than equivalent air-source system.

### GEOTHERMAL COST COMPARISON

As of the schematic design phase (SD), the estimated available square footage for photovoltaic (PV) cells is the following:

- Roof PV array | 28,830sf | +/-400kW array\*
- Parking Lot Canopy PV array | 7,350sf | +/-100kW array\*
- **TOTAL** | 36,180sf | +/-500kW array



#### **PHOTOVOLTAIC SYSTEM ON NEW SCHOOL:**

- 500kW estimated generation = 405,000kWh/year
- 405,000kWh/year x \$0.22/kWh = \$89,100/year\*

**By comparison, the existing school uses:** ~444,000kWh/year

#### **POINTS TO NOTE:**

- New school is 6,000sf bigger
- New school is fully electric
- Utility rate will likely increase in future

\*These numbers are estimates only and are subject to change due to factors such as early design phase and not having the opportunity to meet with the Town Fire Chief.

# PHOTOVOLTAIC SYSTEM



#### Installation Rule of Thumb- \$3500/kW

#### **BUDGETARY NUMBERS:**

SCHOOL ROOF (~400kW)	\$1,400,000	
PARKING LOT CANOPY (~100kW)	\$ 350,000	
PARKING LOT CANOPY FRAMING	\$ 750,000	
PV SYSTEM BUDGET	\$2,500,000	

#### ESTIMATED Town Share After Incentives (30%): \$2,500,000 x 70% = \$1,750,000

### PHOTOVOLTAIC SYSTEM



	Current System (ASHP only)	Hybrid System (Geothermal)	Delta
Annual Energy Consumption (kWh/year) 190,800 total	<b>76,320</b> (40% of 190,800)	<b>76,320</b> (40% of 190,800)	
<ul> <li>Energy Cost per Year (\$0.22/kWh)</li> <li>Air-Source Heat Pumps Only</li> <li>Hybrid System (40%)</li> </ul>	\$16,790	\$10,494	(\$6,296)
1-Year Payback			(\$6 <i>,</i> 296)
10-Year Payback			(62,960)
20-Year Payback			(\$629,600)

#### **Points to Note:**

- A geothermal system is expected to be 25-50% (37.5%) more efficient than equivalent air-source system.
- Due to volatility with future electrical energy costs, values may increase.

### GEOTHERMAL COST COMPARISON

### FIRST FLOOR PLAN

